

**15A NCAC 02Q .0903 EMERGENCY GENERATORS AND STATIONARY RECIPROCATING  
INTERNAL COMBUSTION ENGINES**

(a) For the purposes of this Rule, the following definitions shall apply:

- (1) "Emergency generator" means an emergency stationary reciprocating internal combustion engine, as defined in 40 CFR 63.6675.
- (2) "Stationary reciprocating internal combustion engine" shall be defined as set forth in 40 CFR 63.6675.

(b) This Rule shall apply to emergency generators and stationary reciprocating internal combustion engines at a facility whose only sources that would require a permit are emergency generators and stationary reciprocating internal combustion engines whose facility-wide actual emissions are less than 100 tons per calendar year of any regulated pollutant, 10 tons per calendar year of any hazardous air pollutant, or 25 tons per calendar year of any combination of hazardous air pollutants.

(c) The owner or operator of emergency generators and stationary reciprocating internal combustion engines regulated pursuant to this Rule shall comply with 15A NCAC 02D .0516, .0521, .0524, and .1111.

(d) The owner or operator of emergency generators and stationary reciprocating internal combustion engines regulated pursuant to this Rule shall provide the Director with documentation, upon request, that the emergency generators and stationary reciprocating internal combustion engines meet the applicability requirements set forth in Paragraph (b) of this Rule.

*History Note: Authority G.S. 143-215.3(a); 143-215.107(a)(10); 143-215.108;  
Eff. June 1, 2008;  
Amended Eff. June 13, 2016;  
Readopted Eff. April 1, 2018.*